



Shaffer Beacon MECHANICAL^{LLC}

PRESSURE TEST REPORT

Date: December 8, 2022

Site: Asnuntuck Community College

Equipment	Readings				Result
	0:00	1:00	2:30	4:00	
MAU1	5.0psi	4.7psi	6.0psi	5.0psi	Pass; normal test pressure variation due to outside temperature variation
MAU2	5.0psi	4.7psi	6.0psi	5.0psi	Pass; normal test pressure variation due to outside temperature variation
RTU, Heating Unit	5.0psi	4.5psi	6.0psi	5.0psi	Pass; normal test pressure variation due to outside temperature variation

Note: See attached videos for final soap tests after gas was turned back on

Videos: [Click here](#)